



NOTES:

1. BONDING /GROUNDING DETAIL FOR USE WITH GALVANIZED RIGID STEEL PVC COATED CONDUIT AND PULL BOX WITHIN 10' FROM POLE.
2. THE GROUND ROD SHALL BE INSTALLED AT AN OBLIQUE ANGLE NOT TO EXCEED 45 DEGREES FROM THE VERTICAL.
3. TERMINATE BONDING CONDUCTOR AT POLE GROUNDING LUG WITH UL APPROVED GROUNDING LUG.

APPROVED BY

[Signature]

DATE

3/3/92

POLE BONDING - METHOD B

DEPARTMENT OF PUBLIC WORKS



DRAWING NO.

E-47